



PUBLISHED WARRANTY LIFE CYCLE COMPARISON

Below are Published Life Cycle ratings comparing BAE's OPzS Flooded Tubular and Flat Plate Battery types (OPzS and OGi Series) to one of North Americas most important manufacturers.

Discharge Duration	Competitor A Warranted # Events	BAE OPzS Series Warranted # Events	Approximate Depth of Discharge
0.0 - 30 sec.	5400	15000	12.5% 33.0% 80.0%
30 sec. - 1.5 min.	790	8000	
1.5 min. - 4.0 min.	310	4500	
4.0 min. - 15 min.	135	1500	

Discharge Duration	Competitor B Warranted # Events	BAE OGi Series Warranted # Events	Approximate Depth of Discharge
0.0 - 30 sec.	10500	12000	12.5% 33.0% 80.0%
30 sec. - 1.5 min.	2100	6000	
1.5 min. - 4.0 min.	660	3200	
4.0 min. - 15 min.	300	1100	

Stationary Product Series

- OPzS Series Flooded Tubular Positive Plate Construction
- OGi Series Flooded Flat Plate Construction
- OPzV Series Valve Regulated Tubular Positive Plate Construction
- OGiV Valve Regulated Flat Plate Construction
- SPzV Series Valve Regulated Tubular Positive Plate Construction

Please contact your BAE Dealer for more information.

BAE BATTERIES USA	
(www.BAEBatteriesUSA.com)	
Phone: (715) 247-2262	Fax: (715) 247-5741

BAE ENERGY FROM BATTERIES SINCE 1899